

**Addendum #1**  
to  
**2008 Water System SCADA Improvements**  
**Lake Havasu City**  
Lake Havasu City, Arizona  
Project #WT-7070

Date Issued: May 5, 2008  
Bid Date: May 13, 2008

To: All Plan Holders of Record

**THE BIDDER SHALL ACKNOWLEDGE RECEIPT OF ALL ADDENDA ON THE BID FORM. FAILURE TO DO SO MAY SUBJECT BIDDER TO DISQUALIFICATION. THIS ADDENDUM FORMS PART OF THE BIDDING DOCUMENTS AND MODIFIES THEM AS FOLLOWS:**

***Changes to the Specifications:***

Section 16900A-2.2.B

Correct Part Numbers as follows:  
1763-L16BWA : PLC Processor Module with Base.  
1762-IF4 : Analog Card

Section 16900A-2.2.C

Delete requirement for UHF Lightning Protector. Retain the existing Polyphaser unit.

***Changes to the Drawings:***

Sheet E3 – RTU Enclosure Detail

Clarification: Provide a new enclosure to contain the batteries located to the side and adjacent to the existing battery enclosure. Pending actual physical size of the new batteries, the existing enclosure may not accommodate the new batteries.

END OF ADDENDUM ITEMS



By: Joel A. Kath, PE  
JK Engineers, Inc.

